

Approval Number 2310527
Test Report: J-00464704



22nd March 2024

General De Fundicion Y Accesorios, S.L.
Avda. El Puntarron, 39,
30835 Sangonera La Seca,
Murca,
Spain

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS- FACTORY APPLIED PIPE & FITTINGS COATINGS.

5030

'ZX-9 Zhenxin Epoxy Powder Coating'. Factory applied, blue coloured epoxy coating. Apply as per manufacturer's 'Preparation and Curing Conditions' instructions reference 'ZX-9-1', dated '2024/02/26'. Cure for 30 minutes@180°C. For use with water up to 85°C.

If the curing conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

APPROVAL NUMBER: 2310527

APPROVAL HOLDER: GENERAL DE FUNDICION Y ACCESORIOS, S.L.

The Scheme reserves the right to review approval.

Approval 2310527 is valid between October 2023 and October 2028

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager